



NOTES:

1. THE METER IS FURNISHED BY THE COMMUNITY DEVELOPMENT DEPARTMENT, BUT MUST BE INSTALLED BY THE CUSTOMER. ALL MATERIAL ILLUSTRATED, EXCEPT THE METER, MUST BE SUPPLIED AND INSTALLED BY THE CUSTOMER AND APPROVED.
2. THE INSTALLATION MAY BE PLACED FROM ONE (1) TO TWO (2) FEET OFF THE FLOOR, DEPENDING UPON INSTALLATION REQUIREMENTS AND MUST BE ADEQUATELY SUPPORTED.
3. THE METER MUST BE INSTALLED A MINIMUM OF 18 INCHES AWAY FROM ANY VERTICAL WALL OR OBSTRUCTION.
4. IN READ-O-MATIC INSTALLATIONS WIRE MUST BE INSTALLED IN CONDUIT (ELECTRICAL) OR A RACEWAY, AND CONDUIT MUST TERMINATE WITHIN ONE FOOT OF THE METER.
5. ALL METERS 1 1/2 INCHES OR LARGER IN SIZE MUST HAVE A BYPASS INSTALLED AS SHOWN IN THE ABOVE DRAWING. THE BYPASS CANNOT BE MORE THAN ONE (1) PIPE SIZE SMALLER THAN THE METER SIZE. THE VALVE ON THE BYPASS PIPING MUST BE CAPABLE OF BEING LOCKED OFF.
6. A REDUCED PRESSURE ZONE BACKFLOW PREVENTOR WILL BE REQUIRED ON ALL ALL NEW CONSTRUCTION AND MODIFICATIONS TO THE EXISTING PIPING. THE BACKFLOW PREVENTOR SHALL BE PLACED AFTER THE METER AND ANY BYPASS. PLEASE CONTACT THE WATER DIVISION FOR QUESTIONS ON BACKFLOW INSTALLATION.
7. NO GALVANIZED PIPE ALLOWED BEFORE R.P.Z.

VILLAGE OF ELK GROVE VILLAGE

WATER METER - 1 1/2" OR LARGER

