



NOTE:

1. THE METER IS FURNISHED BY THE ELK GROVE VILLAGE COMMUNITY DEVELOPMENT DEPARTMENT, BUT MUST BE INSTALLED BY THE CUSTOMER. ALL MATERIAL ILLUSTRATED, EXCEPT THE METER, MUST BE SUPPLIED AND INSTALLED BY THE CUSTOMER AND APPROVED BY THE WATER DIVISION OF PUBLIC WORKS.

PLEASE CONTACT THE WATER DIVISION AT:

ELK GROVE VILLAGE PUBLIC WORKS DEPARTMENT
 WATER DIVISION
 450 E DEVON AVENUE
 ELK GROVE VILLAGE, IL 60007
 (847) 734-8800

2. THE INSTALLATION MAY BE PLACED FROM ONE (1) TO TWO (2) FEET OFF THE FLOOR, DEPENDING UPON INSTALLATION REQUIREMENTS AND MUST BE ADEQUATELY SUPPORTED.
3. THE METER MUST BE INSTALLED A MINIMUM OF 18 INCHES AWAY FROM ANY VERTICAL WALL OR OBSTRUCTION.
4. IN READ-O-MATIC INSTALLATIONS WIRE MUST BE INSTALLED IN CONDUIT (ELECTRICAL) OR A RACEWAY, AND CONDUIT MUST TERMINATE WITHIN ONE FOOT OF THE METER.
5. NO GALVANIZED PIPE ALLOWED BEFORE R.P.Z.
6. A REDUCED PRESSURE ZONE BACKFLOW PREVENTOR WILL BE REQUIRED ON ALL ALL NEW COMMERCIAL AND INDUSTRIAL CONSTRUCTION AND MODIFICATIONS TO THE EXISTING PIPING, AS WELL AS ALL RESIDENTIAL METERS 2" OR LARGER OR SYSTEMS WITH AN IRRIGATION SYSTEM. THE BACKFLOW PREVENTOR SHALL BE PLACED AFTER THE METER AND ANY BYPASS. PLEASE CONTACT THE WATER DIVISION FOR QUESTIONS ON BACKFLOW INSTALLATION.

VILLAGE OF ELK GROVE VILLAGE

WATER METER - 1" OR SMALLER

