



ELK GROVE VILLAGE
Soil Erosion and Sedimentation Control Requirements

1. Provide a stabilized construction entrance – in accordance with the Illinois Urban Manual and the NRCS details. Minimum size of stabilized construction entrance shall be 24 feet by 24 feet.
2. Provide inlet basket filters with filter fence around drainage structures.
3. Provide an 18-inch deep trench around the perimeter of all soil stockpiles.
4. Provide straw bales or filter fence where runoff from the site flows onto adjacent properties.
5. Contractor shall immediately remove soil or mud deposited on public streets.
6. Contractor shall inspect the site weekly and after each rainfall to ensure that soil erosion control measures are working properly.
7. Contractor is responsible for the construction, inspection and maintenance of the soil erosion and sedimentation control measures.
8. The contractor shall implement any soil erosion and sedimentation control measures deemed necessary by the Village Engineer.
9. Refer to **Procedures and Standards for Urban Soil Erosion and Sedimentation Control in Illinois (the “Green Book”)** as a guideline for erosion control.